



Fire Test Certificate

This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of

Weepa Products Pty Ltd
3/15 Donkin Street,
West End,
Queensland 4101
Australia

Test standard: AS 1530.8.1:2018

Specimen name: Weepa vent model No. 23-NGBW

Specimen description: Weepa vent model No. 23-NGBW consisting of a polypropylene body nominally 75 mm high x 10 mm wide x 105 mm long with a 316 grade stainless steel ember/vermin guard. The stainless steel guard has three rows of nominal 1.8 mm holes through the face of the guard and is designed to pivot within the body at the top.

The Weepa was tested installed into a standard brick wall with nominal 75 mm high x 110 mm wide x 230 mm clay bricks. In accordance with AS 3959: 2018 Clause 9.4, walls consisting of non-combustible materials of 90 mm minimum thickness are deemed to comply with up to and including BAL-FZ ratings.

Orientation: External face of the wall

A full description of the test specimen and the test results are given in BRANZ Test Report:

Bushfire test FP11420-001 Issue 1

Regulatory authorities are advised to examine test reports before approving any product.

The test results were as follows:

Bushfire Attack Level BAL-A40

The results achieved at a particular peak heat flux level automatically apply to lower heat flux levels with the same size or smaller crib.

Example: If a specimen achieves a BAL of A40 it automatically qualifies for BALs of A29, A19 and A12.5 but not B and C levels because Class B and class C cribs are larger.

Certificate issued: 25 February 2021

Certificate Number: FP11420-001-C1
Issue 1

P Chapman
Senior Fire Testing Engineer
For BRANZ Limited



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.

The National Association of Testing Authorities (NATA) and International Accreditation New Zealand (IANZ) are both signatories of the ILAC Mutual Recognition Agreement.

The following statement is required by the test standard "This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance."